

Appendix 1: WTP Annual Average Daily Flow 2016 - 2020

Water Treatment Plant	Rated Capacity (m ³ /d)	Average Daily Flow (m ³ /d)							3 to 5 Year % Change
		2016	2017	2018	2019	2020	5 Year 2016 - 2020	3 Year 2018 - 2020	
Decew Falls WTP	227,300	54,903	54,321	56,090	53,303	53,390	54,401	54,261	0%
Grimsby WTP	44,000	15,699	14,020	14,866	14,029	15,726	14,868	14,874	0%
Niagara Falls WTP	145,584	47,350	45,192	44,780	43,400	40,145	44,173	42,775	-3%
Port Colborne WTP	36,000	7,719	8,735	8,864	7,282	6,870	7,894	7,672	-3%
Rosehill WTP	50,026	13,148	12,388	12,862	11,188	11,024	12,122	11,691	-4%
Welland WTP	65,000	21,858	21,590	22,538	22,579	24,670	22,647	23,262	3%