

Appendix 2: WWTP Annual Average Daily Flow 2016 - 2020

Wastewater Treatment Plant	Rated Capacity (m <sup>3</sup> /d)	Average Daily Flow (m <sup>3</sup> /d)							3 to 5 Year % Change
		2016	2017	2018	2019	2020	5 Year 2016 - 2020	3 Year 2018 - 2020	
Anger Avenue WWTP	24,500	12,661	15,000	14,624	15,146	13,580	14,202	14,450	2%
Baker Road WWTP	31,280	16,999	20,897	19,975	20,910	17,952	19,347	19,612	1%
Crystal Beach WWTP	9,100	4,676	5,915	5,874	6,276	5,688	5,686	5,946	4%
Niagara Falls WWTP	68,300	35,880	44,684	41,489	41,360	35,242	39,731	39,364	-1%
NOTL WWTP <sup>(1)</sup>	8,000	4,021	4,561	4,687	5,237	5,142	4,730	5,022	6%
Port Dalhousie WWTP	61,350	29,616	34,823	35,095	36,681	34,113	34,065	35,296	3%
Port Weller WWTP	56,180	29,650	32,090	36,881	39,211	33,751	34,317	36,614	6%
Queenston WWTP	500	278	234	198	213	135	212	182	-16%
Seaway WWTP	19,600	9,103	12,082	12,580	13,472	11,299	11,707	12,450	6%
Stevensville/Douglastown Lagoon	2,289	1,314	1,635	1,670	1,729	1,592	1,588	1,664	5%
Welland WWTP	54,550	29,728	35,407	34,643	37,137	33,617	34,107	35,133	3%

Note 1: Effluent discharge from NOTL WWTP started directly on January 6, 2020 after previously used lagoon was gradually decommissioned by January 16, 2020.