

Appendix 1: WTP Annual Average Daily Flow 2017 - 2021

Water Treatment Plant	Rated Capacity (m ³ /d)	Average Daily Flow (m ³ /d)					5 Year Average 2017 / 21	3 Year Average 2019 / 21
		2017	2018	2019	2020	2021		
Decew Falls WTP	227,300	54,349	56,090	53,303	53,390	50,824	53,591	52,506
Grimsby WTP	44,000	14,032	14,919	14,029	15,726	14,872	14,716	14,876
Niagara Falls WTP	145,584	44,924	44,835	43,400	40,145	40,125	42,686	41,223
Port Colborne WTP	36,000	8,735	8,864	7,282	6,870	6,387	7,628	6,846
Rosehill WTP	50,026	12,395	12,872	11,188	11,024	11,710	11,838	11,307
Welland WTP	65,000	21,594	22,538	22,579	24,670	24,675	23,211	23,975