

Appendix 2: WWTP Annual Average Daily Flow 2017 - 2021

Wastewater Treatment Plant	Rated Capacity (m ³ /d)	Average Daily Flow (m ³ /d)					5 Year Average 2017 / 21	3 Year Average 2019 / 21
		2017	2018	2019	2020	2021		
Anger Avenue WWTP	24,500	15,000	14,624	15,146	13,580	13,171	14,304	13,966
Baker Road WWTP	31,280	20,897	19,975	20,910	17,952	17,081	19,363	18,648
Crystal Beach WWTP	9,100	5,915	5,874	6,276	5,688	5,256	5,802	5,740
Niagara Falls WWTP	68,300	44,684	41,489	41,360	35,242	35,197	39,594	37,266
NOTL WWTP	8,000	4,561	4,687	5,237	5,142	5,602	5,046	5,327
Port Dalhousie WWTP	61,350	34,823	35,095	36,681	34,113	31,793	34,501	34,196
Port Weller WWTP	56,180	32,090	36,881	39,211	33,751	33,176	35,022	35,379
Queenston WWTP	500	234	198	213	135	142	185	163
Seaway WWTP	19,600	12,082	12,580	13,472	11,299	10,200	11,927	11,657
Stevensville/Douglastown	2,289	1,635	1,670	1,729	1,592	1,552	1,636	1,624
Welland WWTP	54,550	35,407	34,643	37,137	33,617	34,288	35,019	35,014