

Appendix 1: WTP Annual Average Daily Flow 2018 - 2022

Water Treatment Plant	Rated Capacity (m ³ /d)	Average Daily Flow (m ³ /d)					5 Year Average 2018 / 22	3 Year Average 2020 / 22
		2018	2019	2020	2021	2022		
Decew Falls WTP	227,300	56,090	53,303	53,390	50,824	52,970	53,315	52,395
Grimsby WTP	44,000	14,919	14,029	15,726	14,872	14,809	14,871	15,136
Niagara Falls WTP	145,584	44,835	43,400	40,145	40,125	42,164	42,134	40,811
Port Colborne WTP	36,000	8,864	7,282	6,870	6,387	6,953	7,271	6,737
Rosehill WTP	50,026	12,872	11,188	11,024	11,710	13,025	11,964	11,920
Welland WTP	65,000	22,538	22,579	24,670	24,675	24,162	23,725	24,502