

Appendix 2: WWTP Annual Average Daily Flow 2018 - 2022

Wastewater Treatment Plant	Rated Capacity (m³/d)	Average Daily Flow (m³/d)					5 Year Average 2018 / 22	3 Year Average 2020 / 22
		2018	2019	2020	2021	2022		
Anger Avenue WWTP	24,500	14,624	15,146	13,580	13,171	13,614	14,027	13,455
Baker Road WWTP	31,280	19,975	20,910	17,952	17,081	20,739	19,331	18,591
Crystal Beach WWTP	9,100	5,874	6,276	5,688	5,256	5,352	5,689	5,432
Niagara Falls WWTP	68,300	41,489	41,360	35,242	35,197	39,696	38,597	36,712
NOTL WWTP	8,000	4,687	5,237	5,142	5,602	6,398	5,413	5,714
Port Dalhousie WWTP	61,350	35,095	36,681	34,113	31,793	29,332	33,403	31,746
Port Weller WWTP	56,180	36,881	39,211	33,751	33,176	36,130	35,830	34,352
Queenston WWTP	500	198	213	135	142	168	171	149
Seaway WWTP	19,600	12,580	13,472	11,299	10,200	10,303	11,571	10,601
Stevensville/Douglastown	2,289	1,670	1,729	1,592	1,552	1,496	1,608	1,547
Welland WWTP	54,550	34,643	37,137	33,617	34,288	36,222	35,182	34,709