

Appendix 1: WTP Annual Average Daily Flow 2019 - 2023

---

Water Treatment Plant	Rated Capacity (m <sup>3</sup> /d)	Average Daily Flow (m <sup>3</sup> /d)					5 Year Average 2019 / 23	3 Year Average 2021 / 23
		2019	2020	2021	2022	2023		
Decew Falls WTP	227,300	53,303	53,390	50,824	52,970	52,830	52,663	52,208
Grimsby WTP	44,000	14,029	15,726	14,872	14,809	14,610	14,809	14,764
Niagara Falls WTP	145,584	43,400	40,145	40,125	42,164	43,050	41,777	41,780
Port Colborne WTP	36,000	7,282	6,870	6,387	6,953	8,310	7,160	7,217
Rosehill WTP	50,026	11,188	11,024	11,710	13,025	12,710	11,931	12,482
Welland WTP	65,000	22,579	24,670	24,675	24,162	24,100	24,037	24,312