

Appendix 2: WWTP Annual Average Daily Flow 2019 - 2023

Wastewater Treatment Plant	Rated Capacity (m³/d)	Average Daily Flow (m³/d)					5 Year Average 2019 / 23	3 Year Average 2021 / 23
		2019	2020	2021	2022	2023		
Anger Avenue WWTP	24,500	14,624	15,146	13,580	13,171	12,992	13,903	13,248
Baker Road WWTP	31,280	19,975	20,910	17,952	17,081	23,700	19,923	19,578
Crystal Beach WWTP	9,100	5,874	6,276	5,688	5,256	5,423	5,703	5,456
Niagara Falls WWTP	68,300	41,489	41,360	35,242	35,197	42,902	39,238	37,780
NOTL WWTP	8,000	4,687	5,237	5,142	5,602	6,823	5,498	5,856
Port Dalhousie WWTP	61,350	35,095	36,681	34,113	31,793	29,176	33,372	31,694
Port Weller WWTP	56,180	36,881	39,211	33,751	33,176	38,024	36,208	34,983
Queenston WWTP	500	198	213	135	142	225	183	168
Seaway WWTP	19,600	12,580	13,472	11,299	10,200	11,391	11,789	10,964
Stevensville/Douglstown	2,289	1,670	1,729	1,592	1,552	1,479	1,604	1,541
Welland WWTP	54,550	34,643	37,137	33,617	34,288	39,800	35,897	35,902