

Appendix 2: Wastewater Treatment Plant Annual Average Daily Flow 2020 - 2024

Wastewater Treatment Plant (WWTP)	Rated Capacity (m ³ /d)	2020 Average Daily Flow (m ³ /d)	2021 Average Daily Flow (m ³ /d)	2022 Average Daily Flow (m ³ /d)	2023 Average Daily Flow (m ³ /d)	2024 Average Daily Flow (m ³ /d)	5 Year Average 2020 / 24	3 Year Average 2022 / 24
Anger Avenue WWTP	24,500	15,146	13,580	13,171	12,992	12,084	13,395	12,749
Baker Road WWTP	31,280	20,910	17,952	17,081	23,700	22,100	20,348	20,960
Crystal Beach WWTP	9,100	6,276	5,688	5,256	5,423	4,865	5,501	5,181
Niagara Falls WWTP	68,300	41,360	35,242	35,197	42,902	41,748	39,290	39,949
NOTL WWTP	8,000	5,237	5,142	5,602	6,823	6,217	5,804	6,214
Port Dalhousie WWTP	61,350	36,681	34,113	31,793	29,176	27,416	31,836	29,462
Port Weller WWTP	56,180	39,211	33,751	33,176	38,024	36,429	36,118	35,876
Queenston WWTP	500	213	135	142	225	175	178	181
Seaway WWTP	19,600	13,472	11,299	10,200	11,391	9,519	11,176	10,370
Stevensville/Douglastown	2,289	1,729	1,592	1,552	1,479	1,400	1,550	1,477
Welland WWTP	54,550	37,137	33,617	34,288	39,800	34,801	35,929	36,296