

## APPENDIX 1

## ANNUAL AVERAGE DAILY FLOW 2015 TO 2019 WATER TREATMENT PLANTS

Water Treatment Facility Location	Rated Capacity (m <sup>3</sup> /d)	Average Daily Flow (m <sup>3</sup> /d) 2015	Average Daily Flow (m <sup>3</sup> /d) 2016	Average Daily Flow (m <sup>3</sup> /d) 2017	Average Daily Flow (m <sup>3</sup> /d) 2018	Average Daily Flow (m <sup>3</sup> /d) 2019	5 Year Average Daily Flow (m <sup>3</sup> /d) 2015 to 2019
Decew Falls WTP	227,300	53,723	54,903	54,321	56,090	53,303	54,468
Grimsby WTP	44,000	16,652	15,699	14,020	14,866	14,029	15,053
Niagara Falls WTP	145,584	45,186	47,350	45,192	44,780	43,400	45,182
Port Colborne WTP	36,000	8,908	7,719	8,735	8,864	7,282	8,302
Rosehill WTP	50,026	13,182	13,148	12,388	12,862	11,188	12,554
Welland WTP	65,000	20,164	21,858	21,590	22,538	22,579	21,746

Note 1: Welland WTP rated capacity changed from 102,300 m<sup>3</sup>/d to 65,000 m<sup>3</sup>/d due to Operational constraints.