

APPENDIX 2

ANNUAL AVERAGE DAILY FLOW 2015 TO 2019 WASTEWATER TREATMENT PLANTS

	Rated	Average	Average	Average	Average	Average	5 year
	Capacity	Daily Flow	Daily Flow	Daily Flow	Daily Flow	Daily Flow	Average
Wastewater Treatment	(m ³ /d)	(m ³ /d)	(m ³ /d)	(m ³ /d)	(m ³ /d)	(m ³ /d)	Daily Flow
Facility Location							(m ³ /d)
		2015	2016	2017	2018	2019	2015 to 2019
Anger Avenue WWTP	24,500	12,755	12,661	15,000	14,624	15,146	14,037
Baker Road WWTP	31,280	17,549	16,999	20,897	19,975	20,910	19,266
Crystal Beach WWTP	9,100	5,005	4,676	5,915	5,874	6,276	5,549
Niagara Falls WWTP	68,300	40,782	35,880	44,684	41,489	41,360	40,839
NOTL WWTP	8,000	3,911	4,021	4,561	4,687	5,237	4,483
Port Dalhousie WWTP	61,350	30,091	29,616	34,823	35,095	36,681	33,261
Port Weller WWTP	56,180	30,856	29,650	32,090	36,881	39,211	33,738
Queenston WWTP	500	234	278	234	198	213	231
Seaway WWTP	19,600	11,064	9,103	12,082	12,580	13,472	11,660
Stevensville/Douglastown Lagoon	2,289	1,192	1,314	1,635	1,670	1,729	1,508
Welland WWTP	54,550	32,164	29,728	35,407	34,643	37,137	33,816